



April 3, 2023

Your Unitil Account Number: [Redacted]

Dear [Redacted]

Recently you requested that Unitil test your electric meter to ensure it is measuring accurately. The specifics of the test are listed below:

Meter Test for Account #:	[Redacted]
Date of Request:	03/29/2023
Location of Meter:	[Redacted]
Type:	1ph self contained
Make:	Landis and Gyr
Size:	AXRE-SD
Serial #:	160999609
Meter #:	501808
Date of Test:	
Weighted Average:	100.06

We completed the testing on the meter listed above and found it to be registering accurately and within the 2% variance allowed by the NH Public Utilities Commission (PUC), and in accordance with our rules and regulations approved by the PUC and on file in their office.

If you still consider your bill to be inaccurate in any respect, or if you have any other concern pertaining to this matter, you have the right to appeal to the NH Public Utilities Commission at:

NH Public Utilities Commission  
Consumer Division  
21 South Fruit Street, Suite 10  
Concord NH 03301-2429  
(800) 852-3793

Sincerely,

Unitil Customer Service