

**THE STATE OF NEW HAMPSHIRE
BEFORE THE
DEPARTMENT OF ENERGY**

**PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
d/b/a EVERSOURCE ENERGY**

DOCKET No. CR 2022-

**PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A
EVERSOURCE ENERGY FOR A LICENSE TO CONSTRUCT AND MAINTAIN
ELECTRIC LINES OVER AND ACROSS PUBLIC WATERPUBLIC WATER IN
GOFFSTOWN, NEW HAMPSHIRE**

Pursuant to RSA 371:17, Public Service Company of New Hampshire d/b/a Eversource Energy (“Eversource”), a public utility engaged in the transmission, distribution and sale of electricity in the State of New Hampshire, hereby petitions the Department of Energy (“Department”), for a license to construct and maintain electric lines over and across public water in Goffstown, New Hampshire. In support of this petition Eversource states as follows:

1. In order to meet the requirements for reasonable service to the public, Eversource has previously constructed and currently operates and maintains an overhead 115 kV electrical transmission line, designated as the Eversource C196 Line, originally constructed in 1968, over and across public waters in Goffstown, New Hampshire. The public water crossing that is included in this petition was previously licensed in 2010 under DE- 10-232 (Order No. 25,157) for the addition of optical ground wire (OPGW).

2. As part of its ongoing asset condition inspection program, Eversource determined that the existing wood Structures 143 and 144 at the public water crossing need to be replaced to continue to function safely and reliably. Structure 143 will be replaced with weathering steel equivalent that will be located within 10’ of the original structure location. Shortly after the Structure 143 replacement is completed and in conjunction with a maintenance project planned for the Greggs substation located near Str. 144, which is anticipated to commence in 2023, the existing wood three pole Structure 144 will be replaced with a single pole engineered weathered steel structure,

which will be located within 10' of the original structure location. Also as part of the Greggs substation improvements, the C196's existing three 795 ACSR 36/1 conductors will be replaced with 1272 ACSS 54/19 conductor. The OPGW and static wires between Structures 143 and 144 will be unchanged in the course of relocation to the replacement steel structure. The proposed wire specifications are identified on Exhibit 3.

3. The location of the public water crossing which is the subject of this petition, is depicted on the Overview Map attached hereto as Exhibit 1 and a more detailed location description is as follows:

Exhibit 2 – The C196 Line crosses Glen Lake commencing at Structure 143 immediately south from where the C196 Line crosses Elm Street in Goffstown, which is approximately 325 feet east from the entrance to the Glen Lake School and approximately 400 feet west from the Glen Lake Public Boat Ramp on Elm Street. The waterbody crossing extends south approximately 1,182 feet to Structure 144, where the line turns 90 degree east into the Greggs Substation, which is located off Mast Road in Goffstown between the Goffstown Rail Trail Parking Lot and the Greggs Falls Dam/Hydroelectric station.

4. Wire specifications and loading condition to establish maximum sag for the crossing span that is the subject of this petition are as indicated on Profile View and Cable Schedule of Exhibit 2 and 3. The 100 year flood elevation for Glen Lake was derived from FEMA's National Flood Hazard Layer Firmette, accessed on May 17, 2022.

5. The location of structures and max sag conditions creates the following crossing span:

- (a) Public water Crossing: Goffstown - Glen Lake (Exhibit 2 and 3)
 - i. Structures: 143 to 144
 - ii. Structure Span (ft): 1,182.1
 - iii. Public water Span (ft): 932.7

6. All conductors and wires have been drawn on Exhibit 2 to show the minimum clearance at maximum sag conditions in reference to the public water crossing.

7. Eversource will maintain and operate the clearances of the crossings at a height no less than what is required by the 2012 National Electrical Safety Code (NESC, Table 232-1) which is 30.1' for 115 kV conductor over water areas suitable for sail boating including lakes, ponds,

reservoirs, tidal waters, rivers, streams, and canals with an unobstructed surface area of over 20 to 200 acres. The actual minimum height over the public water is depicted on the attached Exhibit 2 and exceeds the respective minimum requirements.

8. A New Hampshire Department of Environmental Services (NHDES) wetland statutory permit by notification (SPN) and shoreland permit by notification (PBN) will be required to account for temporary wetland and shoreland buffer impacts associated with the replacement of Structure 143. The SPN and PBN will be obtained prior to commencement of construction.

9. The structure replacement work will be accomplished within existing Eversource easements thereby mitigating impacts and concerns of property owners affected by the project scope. When wires are being transferred, Eversource will ensure the public water is clear of any persons before work commences. Additionally, a guard structure will be utilized when wires are being transferred from the old structure to the new to further protect the general public.

10. Eversource submits that the license petitioned for herein may be exercised without substantially affecting the use and enjoyment of the public water because safe clearances will be maintained at all times and appropriate precautions to ensure the safety of recreational users will be undertaken while the maintenance work is performed.

WHEREFORE, Eversource respectfully requests that the Department:

1. Find that the license petitioned for herein may be exercised without substantially affecting the public rights in the public water crossing which is the subject of this petition;
2. Grant Eversource a license to construct and maintain electric lines over and across public water described in this petition;

Dated at Manchester, New Hampshire this 22nd day of July, 2022.

Respectfully submitted,
PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
D/B/A EVERSOURCE ENERGY
By Its Attorney



Erik R. Newman, Senior Counsel, Legal
780 North Commercial Street
Manchester, NH 03101
(603) 634-2459