



Michael J. Sheehan, Esq.
Director, Legal Services
Phone: 603-724-2135
Michael.Sheehan@libertyutilities.com

July 2, 2024

Via Electronic Mail Only

New Hampshire Department of Energy
21 South Fruit Street
Concord, New Hampshire 03301-2429

**Re: NHDOE RUL 2024-004 (Rulemaking Notice No. 2024-92)
En 300 Rules for Electric Service
Liberty Comments on Initial Proposal**

On behalf Liberty Utilities (Granite State Electric) Corp., d/b/a Liberty, I write with further comments on the proposed En 300 rules that I neglected to include in the letter filed earlier today.

En 305.03

Liberty previously asked the Department to consider reducing the number of meters to be tested each year in proposed EN 305.03(c)(1) b.i. from "at least 1% of meters in use but not fewer than 500 meters" to "at least 0.5% of meters in use but not fewer than 250 meters."

In addition to that request, and for the same reasons, Liberty asks the Department to consider the following changes to proposed En 305.03(c)(2), (3), and (4):

(2) Self-contained polyphase meters, each meter no less than once every ~~12~~ 24 years;

(3) Single-phase transformer-rated meters, each meter no less than once every ~~8~~ 16 years; and

(4) Polyphase transformer-rated meters, each meter no less than once every ~~4~~ 8 years.

Thank you.

Sincerely,

A handwritten signature in dark ink, appearing to read "M. Sheehan", written in a cursive style.

Michael J. Sheehan